



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO - ws/lab/120/2026

Date - 25/04/2026


To
The Principal,
Darshan Academy,
Chinchwad.


Subject: Water sample Potability Certificate.


Drinking water sample provided by Darshan Academy, Chinchwad on Date: 24/04/2026 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /116/2026 dated 25/04/2026 & ws /lab /118/2026 dated 25/04/2026 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Noida, Pune 44







PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Darshan Academy

No-WS/LAB/116 /2026

Date - 25 / 04 /2026

ADDRESS - Chinchwad.

Date of Receipt - 24 / 04 /2026

SOURCE -

Date of Examination - 24 / 04 /2026

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.30 NTU.		
2	pH	6.5 to 8.5	7.50		
3	Total Hardness (as CaCO ₃)	200 mg/lit	84 mg/lit.		
4	Chloride	250 mg/lit	28 mg/lit.		
5	Calcium	75 mg/lit	17.63 mg/lit.		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

[Signature]

[Signature]

[Signature]

CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/118 /2026

Date - 25/04/2026

DATE OF EXAMINATION - 24/04/2026

NAME - Darshan Academy

ADDRESS - Chinchwad

SOURCE -

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	Nil	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					

CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Mgdi, Pune 44

Vinay Seth

DK